



Wire instruction for CE
completions see Wire-
diagram W96-0318-1

Replace W97z50-75

Correction:

Weight kg	Total Loss Watt
ca4 kg	140W/60A 170W/80A

Målskisse/Outline

W2C.....V.....A+OPT500+BF

SOLID STATE POWER

60-500V 60 - 80 AMP

TEGN. H.W:

TILBUDS NR.

ORDRE NR.

Varenr.; 60A/80A:14-238/239

W14Z50-80

SEMIKRAFT DROBAK